



Islamic Republic of Afghanistan

Ministry of Finance

Office of the Deputy Minister for Administration

Procurement Directorate

Amendment N# 1

ISLAMIC REPUBLIC OF AFGHANISTAN

MINISTRY OF FINANCE

Procurement Directorate

The following modifications are made through this amendment after pre -bid meeting queries against project”
Procurement of DR Data center for Pashtany Bank. Ref Number MASOB/AF/G-17.

S/N	Question	Answer
1	As per Tender document (SBD) Point Number 4 and 9 : UPS quantities are asked as 2 units while PDUs are requested only 4 No's. Same should be 8 no's to utilize dual power from 2 different ups? Please clarify.	Yes, It should be 8 No's.
2	As per Tender document (SBD) Point Number 1 In line item 1.1 :cable tray is requested for 300x50mm while in Line 1.20 it is written as 200x50mm.so kindly correct the quantity/Size?	This will be 300x70mm.
3	As per Tender document (SBD) Point Number 1 What is requested in line item 1.20 : (30 Sq. Mtr) - cable tray or other? As raise floor is requested for 120 sq. mtr.in line item 1.4, please clarify?	Raise floor 50 Sq. Meter

4	As per Tender document (SBD) Point Number 1 and Line no 1.3: Fireproof painting – 70 sq. meter mentioned in line item 1.3 is never possible (same need to be increased as per actual) if line item 1.4 is 120 sq. mtr.). What about painting in Power room?	Painting for inside DC only is 180 Sq. Meter.
5	As per Tender document (SBD) Point Number 5: let us know the correct quantity of AVR?	It is Single.
6	As per Tender document (SBD) Point Number 11 :AXIS P3365-VE is end of life. Can we quote as deferent Brand with same spec in place of AXIS. Please confirm?	Yes, Bidder can quote the different BRAND but it must have the equivalent specification mentioned in the RFP.
7	As per Tender document (SBD) Point Number 8: Should we quote - Vertiv branded Rack which is equal to APC rack, please confirm?	Yes, Bidder can quote the different BRAND but it must have the equivalent specification mentioned in the RFP.
8	As per Tender document (SBD) Point Number 8: Under The Dell/APC racks the qty required is 4 including 8 port KVM switch. But in the spec requirement the qty mentioned is 2 so need to confirm what is required.	It is 4 Quantity.
9	As per Tender document (SBD) Point Number Point Number 3 : Specification are ok but product name is not declared	Shield or Equivalent.
10	Should MAF is required for the following products PRECISION AC, UPS - 30 KVA, AVR (AUTOMATIC VOLTAGE STABALIZER), So that MOF/Pashtany bank can avoid the refurbished products, please confirm?	<p>Yes, Manufacture Authorization Letter is MUST for the Following products PRECISION AC, UPS - 30 KVA, AVR (AUTOMATIC VOLTAGE STABALIZER).</p> <p>The Bidder should be Manufacturer’s Authorized partner at the time of participation and should provide manufacturer authorization letter directly from the manufacturer. MAF issued by distributors or resellers are not valid</p>
11	Please confirm the correct quantity for the IP BASED DOOR ACCESS CONRTOL System?	It is 2 Quantity.

12	As per Tender document (SBD) Point Number - 8,Dell/APC racks the quantity required is 4 including 8 port KVM switch, But in the specs, requirement of the 1.3 KVM qty are 2 only, please correct the actual quantity?	It is 4 Quantity.
13	13. There is no details about applicable Taxes and PAYMENT TERM, so kindly clarify?	Taxes are applicable as per the Afghanistan taxation system
14	Location of the DR Site (Kabul or other provinces) 0	Mazar
15	As per Tender document (SBD) Point Number DC & FM200 room dimension need to be collect, kindly arrange the site visit?	Refer Building Plan as shared in Tender already. For More detail Bidder can do site survey
16	What if requested quantity of power cables find short in length during implementation, who will be responsible for same?	It is Bidder Responsibility.
17	Kindly confirm the type of Raise floor tile?	Type 6, Calcium Sulfate.
18	Does MAF required for each item listed in the BOQ? Because there are many items for them, MAF is not possible and cannot be obtained.	Yes, Manufacture Authorization Letter is MUST for the Following products PRECISION AC, UPS - 30 KVA, AVR (AUTOMATIC VOLTAGE STABILIZER). The Bidder should be Manufacturer's Authorized partner at the time of participation and should provide manufacturer authorization letter directly from the manufacturer. MAF issued by distributors or resellers are not valid
19	Delivery Terms: Who will pay the Custom Duty in Afghanistan for Custom Clearance?	The client will pay the custom duty
20	Payment terms are not defined in the bid document, kindly define the payment terms.	On Shipment/Delivery: Ninety (90) percent of the Contract Price of the Goods shipped shall be paid by bank transfer on receipt of the Goods and upon submission of documents specified in GCC Clause 13. On Acceptance: Ten (10) percent of the Contract Price of Goods received shall be paid within thirty (30) days of receipt of the Goods upon submission of claim supported by the Acceptance Certificate for the respective delivery issued by the Purchaser representative in the proforma given in Section VII
21	Price sheet to be filled as per Group C Table mentioned in the bid document at page no. 50 or as per the table where the items& qty are	As per BOQ price schedule.

	mentioned mentioned?	
22	In item no. 1.4 is mentioned Raised Floor but at the Quantity column is mentioned 800Kg weigh which totally irrelevant to the item, therefore please clarify the nature of item.	50 Sq. Meter
23	Floor plan of DC room is to be submitted at the time of bidding or should be submitted before the installation work?.	Refer Building Plan as shared in Tender already
24	The DC door is already installed? If not then, who will supply & fix the DC door bidder or purchaser?	Bidder Responsibility to provide bullet proof door
25	Kindly provide the DC dimensions (LxWxH)	Refer Building Plan as shared in Tender already
26	In items no. 5 AVR you have not mentioned the capacity of AVR? Kindly define the capacity of AVR and correct no. of quantity while you mentioned 2 units in upper heading but 1Qty is mentioned in quantity column.	Quantity one, 120 Kva
27	Due to the queries and its response time, we would request you to please extend the bid submission time for 2 weeks at least.	The extension is not possible
28	Where is exact and final location for delivery of items	Mazar-e-Saharif
29	Where is final destination of project implementation as from drawings it seem that implementation site is in Mazar-e-Sharif?	Mazar-e-Sharif
30	If later we face some difficulties from whom we can ask ?	Pashtany Bank management and IT Team
31	The capacity for UPS is specified but for stabilizer nothing is mentioned in bid documents, could you please let us know about the capacity of stabilizer?	Quantity one, 120 Kva
32	For big items we will provide the MAF but for small items which is more in numbers how we can provide the MAF dose the MAF required for over all 100% items ?	<p>Yes. Manufacture Authorization Letter is MUST for the Following products PRECISION AC, UPS - 30 KVA, AVR (AUTOMATIC VOLTAGE STABALIZER).</p> <p>The Bidder should be Manufacturer's Authorized partner at the time of participation and should provide manufacturer authorization letter directly from the manufacturer. MAF issued by distributors or resellers are</p>

33	If the site is out of Kabul and located in province so who will be responsible for delivery of goods.	The action will be done as per the specifications stated SBD
34	Where is the location of data center ?	Mazar-e-Sharif